

Technical parameters for heat pump space heaters and heat pump combination heaters

Model(s):	HM121MRS UB40 / HM123MRS UB40	
Air-to-water heat pump:	YES	NO
Water-to-water heat pump:	YES	NO
Brine-to-water heat pump:	YES	NO
Low-temperature heat pump:	YES	NO
Equipped with a supplementary heat pump:	YES	NO
Heat pump combination heater:	YES	NO

Parameters shall be declared for medium-temperature application, except for low-temperature heat pumps.

For low-temperature heat pumps, parameters shall be declared for low-temperature application.

Parameters shall be declared for average climate conditions.

Low temperature application

Item	Symbol	Value	Unit
Rated heat output (*)	$P_{rated}$	12	kW
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature $T_j$			
$T_j = -7 °C$	$P_{dh}$	10.17	kW
$T_j = +2 °C$	$P_{dh}$	6.19	kW
$T_j = +7 °C$	$P_{dh}$	4.50	kW
$T_j = +12 °C$	$P_{dh}$	5.20	kW
$T_j =$ bivalent temperature	$P_{dh}$	11.50	kW
$T_j =$ operation limit temperature	$P_{dh}$	11.50	kW
For air-to-water heat pumps: $T_j = -15 °C$ (if TOL < -20°C)	$P_{dh}$	x, x	kW
Bivalent temperature	$T_{biv}$	-10	°C
Cycling interval capacity for heat	$P_{cyc}$	x, x	kW
Degradation co-efficient(**)	$C_{dh}$	0.9	

Item	Symbol	Value	Unit
Seasonal space heating energy efficiency $\eta_s$		184%	
Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature $T_j$			
$T_j = -7 °C$	COPd or PERd	3.10	- or %
$T_j = +2 °C$	COPd or PERd	4.39	- or %
$T_j = +7 °C$	COPd or PERd	6.40	- or %
$T_j = +12 °C$	COPd or PERd	8.50	- or %
$T_j =$ bivalent temperature	COPd or PERd	2.55	- or %
$T_j =$ operation limit temperature	COPd or PERd	2.55	- or %
For air-to-water heat pumps: $T_j = -15 °C$ (if TOL < -20°C)	COPd or PERd	x, xx	- or %
Cycling interval efficiency	COPcyc or PERcyc	x, xx	- or %
Heating water operating limit temperature	$\tau$ WTOL	65	°C

Medium temperature application

Item	Symbol	Value	Unit
Rated heat output (*)	$P_{rated}$	12	kW
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature $T_j$			
$T_j = -7 °C$	$P_{dh}$	10.21	kW
$T_j = +2 °C$	$P_{dh}$	6.25	kW
$T_j = +7 °C$	$P_{dh}$	4.60	kW
$T_j = +12 °C$	$P_{dh}$	4.60	kW
$T_j =$ bivalent temperature	$P_{dh}$	10.21	kW
$T_j =$ operation limit temperature	$P_{dh}$	10.75	kW
For air-to-water heat pumps: $T_j = -15 °C$ (if TOL < -20°C)	$P_{dh}$	x, x	kW
Bivalent temperature	$T_{biv}$	-7	°C
Cycling interval capacity for heat	$P_{cyc}$	x, x	kW
Degradation co-efficient(**)	$C_{dh}$	0.9	

Item	Symbol	Value	Unit
Seasonal space heating energy efficiency $\eta_s$		136%	
Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature $T_j$			
$T_j = -7 °C$	COPd or PERd	2.08	- or %
$T_j = +2 °C$	COPd or PERd	3.39	- or %
$T_j = +7 °C$	COPd or PERd	4.63	- or %
$T_j = +12 °C$	COPd or PERd	6.79	- or %
$T_j =$ bivalent temperature	COPd or PERd	2.08	- or %
$T_j =$ operation limit temperature	COPd or PERd	1.75	- or %
For air-to-water heat pumps: $T_j = -15 °C$ (if TOL < -20°C)	COPd or PERd	x, xx	- or %
For air-to-water heat pumps: Operation limit temperature	TOL	-15	°C
Cycling interval efficiency	COPcyc or PERcyc	x, xx	- or %
Heating water operating limit temperature	$\tau$ WTOL	65	°C

Power consumption in modes other than active mode			
Off mode	$P_{OFF}$	0.010	kW
Thermostat-off mode	$P_{TO}$	0.030	kW
Standby mode	$P_{SB}$	0.010	kW
Crankcase heater mode	$P_{CK}$	0.000	kW

Supplementary heater			
Rated heat output (*)	$P_{sup}$	5.6	kW
Type of energy input	Electric		

Other items			
Capacity control	Variable		
Sound power level, indoors/outdoor	$L_{WA, indoor}$		dB
	$L_{WA, outdoor}$	60	dB
Annual electricity consumption (Low Temp)	Q HE, (Low Temp)	5086	kWh
Annual electricity consumption (Mid Temp)	Q HE (Mid Temp)	6881	kWh

For air-to-water heat pumps: Rated air flow rate, outdoors (Low Temp)		2388	m <sup>3</sup> /h
For air-to-water heat pumps: Rated air flow rate, outdoors (Mid Temp)		3690	m <sup>3</sup> /h
For water-/brine-to-water heat pumps: Rated brine or water flow rate, outdoor heat exchanger		x	
Water Pump EEI	$\leq$	0.23	
"The benchmark for the most efficient circulators is $EEI \leq 0.20$ ."			

For heat pump combination heater			
Declared load profile		x	
Daily electricity consumption	$Q_{elec}$	x, xxx	kWh
Annual electricity consumption	AEC	x	kWh

Water heating energy efficiency	$\eta_{wh}$	x	%
Daily fuel consumption	$Q_{fuel}$	x, xxx	kWh
Annual fuel consumption	AFC	x	GJ

Contact details  
 Name : Christianna Papazahariou  
 Position : European Regulatory Manager  
 E-mail address : chris.papazahariou@lge.com Tel. 01 49 89 57 41 - 06 83 077 455  
 Postal address : Paris Nord II - 117 avenue des Nations BP 59372  
 Villepinte - 95942 Roissy CDG Cedex  
 www.lg.com

(\*) For heat pump space heaters and heat pump combination heaters, the rated heat output  $P_{rated}$  is equal to the design load for heating  $P_{designh}$ , and the rated heat output of a supplementary heater  $P_{sup}$  is equal to the supplementary capacity for heating  $sup(T_j)$ .

(\*\*) If  $C_{dh}$  is not determined by measurement then the default degradation coefficient is  $C_{dh} = 0.9$ .

**Warmer climate**

**Low temperature application**

Item	Symbol	Value	Unit
Rated heat output (*)	$P_{rated}$	10	kW
Declared capacity for heating for part load at indoor temperature 20 ° C and outdoor temperature $T_j$			
$T_j = + 2 ° C$	$P_{dh}$	10.30	kW
$T_j = + 7 ° C$	$P_{dh}$	6.65	kW
$T_j = + 12 ° C$	$P_{dh}$	5.05	kW
$T_j =$ bivalent temperature	$P_{dh}$	10.30	kW
$T_j =$ operation limit temperature	$P_{dh}$	10.30	kW
For air-to-water heat pumps: $T_j = -15 ° C$ (if TOL < -20°C)	$P_{dh}$	x, x	kW
Bivalent temperature	$T_{biv}$	2	°C
Cycling interval capacity for heat	$P_{cyc}$	x, x	kW
Degradation co-efficient(**)	$C_{dh}$	0.9	

Item	Symbol	Value	Unit
Seasonal space heating energy efficiency $\eta_s$		233%	
Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 ° C and outdoor temperature $T_j$			
$T_j = + 2 ° C$	COPd or PERd	3.60	- or %
$T_j = + 7 ° C$	COPd or PERd	5.40	- or %
$T_j = + 12 ° C$	COPd or PERd	7.50	- or %
$T_j =$ bivalent temperature	COPd or PERd	3.60	- or %
$T_j =$ operation limit temperature	COPd or PERd	3.60	- or %
For air-to-water heat pumps: $T_j = -15 ° C$ (if TOL < -20°C)	COPd or PERd	x, xx	- or %
Cycling interval efficiency	COP <sub>cyc</sub> or PER <sub>cyc</sub>	x, xx	- or %

**Medium temperature application**

Item	Symbol	Value	Unit
Rated heat output (*)	$P_{rated}$	14	kW
Declared capacity for heating for part load at indoor temperature 20 ° C and outdoor temperature $T_j$			
$T_j = + 2 ° C$	$P_{dh}$	14.10	kW
$T_j = + 7 ° C$	$P_{dh}$	9.06	kW
$T_j = + 12 ° C$	$P_{dh}$	4.50	kW
$T_j =$ bivalent temperature	$P_{dh}$	14.10	kW
$T_j =$ operation limit temperature	$P_{dh}$	14.10	kW
For air-to-water heat pumps: $T_j = -15 ° C$ (if TOL < -20°C)	$P_{dh}$	x, x	kW
Bivalent temperature	$T_{biv}$	2	°C
Cycling interval capacity for heat	$P_{cyc}$	x, x	kW
Degradation co-efficient(**)	$C_{dh}$	0.9	

Item	Symbol	Value	Unit
Seasonal space heating energy efficiency $\eta_s$		170%	
Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 ° C and outdoor temperature $T_j$			
$T_j = + 2 ° C$	COPd or PERd	2.34	- or %
$T_j = + 7 ° C$	COPd or PERd	3.64	- or %
$T_j = + 12 ° C$	COPd or PERd	5.70	- or %
$T_j =$ bivalent temperature	COPd or PERd	2.34	- or %
$T_j =$ operation limit temperature	COPd or PERd	2.34	- or %
For air-to-water heat pumps: $T_j = -15 ° C$ (if TOL < -20°C)	COPd or PERd	x, xx	- or %
Cycling interval efficiency	COP <sub>cyc</sub> or PER <sub>cyc</sub>	x, xx	- or %

Annual electricity consumption (Low Temp)	Q HE, (Low Temp)	2330	kWh
Annual electricity consumption (Mid Temp)	Q HE (Mid Temp)	4351	kWh

**Colder climate**

**Low temperature application**

Item	Symbol	Value	Unit
Rated heat output (*)	$P_{rated}$	14	kW
Declared capacity for heating for part load at indoor temperature 20 ° C and outdoor temperature $T_j$			
$T_j = - 7 ° C$	$P_{dh}$	8.48	kW
$T_j = + 2 ° C$	$P_{dh}$	5.20	kW
$T_j = + 7 ° C$	$P_{dh}$	4.70	kW
$T_j = + 12 ° C$	$P_{dh}$	4.90	kW
$T_j =$ bivalent temperature	$P_{dh}$	8.48	kW
$T_j =$ operation limit temperature	$P_{dh}$	9.60	kW
For air-to-water heat pumps: $T_j = -15 ° C$ (if TOL < -20°C)	$P_{dh}$	x, x	kW
Bivalent temperature	$T_{biv}$	-7	°C
Cycling interval capacity for heat	$P_{cyc}$	x, x	kW
Degradation co-efficient(**)	$C_{dh}$	0.9	

Item	Symbol	Value	Unit
Seasonal space heating energy efficiency $\eta_s$		133%	
Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 ° C and outdoor temperature $T_j$			
$T_j = - 7 ° C$	COPd or PERd	3.07	- or %
$T_j = + 2 ° C$	COPd or PERd	4.40	- or %
$T_j = + 7 ° C$	COPd or PERd	6.30	- or %
$T_j = + 12 ° C$	COPd or PERd	7.89	- or %
$T_j =$ bivalent temperature	COPd or PERd	3.07	- or %
$T_j =$ operation limit temperature	COPd or PERd	2.50	- or %
For air-to-water heat pumps: $T_j = -15 ° C$ (if TOL < -20°C)	COPd or PERd	x, xx	- or %
Cycling interval efficiency	COP <sub>cyc</sub> or PER <sub>cyc</sub>	x, xx	- or %

**Medium temperature application**

Item	Symbol	Value	Unit
Rated heat output (*)	$P_{rated}$	15	kW
Declared capacity for heating for part load at indoor temperature 20 ° C and outdoor temperature $T_j$			
$T_j = - 7 ° C$	$P_{dh}$	8.78	kW
$T_j = + 2 ° C$	$P_{dh}$	5.35	kW
$T_j = + 7 ° C$	$P_{dh}$	4.80	kW
$T_j = + 12 ° C$	$P_{dh}$	4.30	kW
$T_j =$ bivalent temperature	$P_{dh}$	8.78	kW
$T_j =$ operation limit temperature	$P_{dh}$	9.40	kW
For air-to-water heat pumps: $T_j = -15 ° C$ (if TOL < -20°C)	$P_{dh}$	x, x	kW
Bivalent temperature	$T_{biv}$	-7	°C
Cycling interval capacity for heat	$P_{cyc}$	x, x	kW
Degradation co-efficient(**)	$C_{dh}$	0.9	

Item	Symbol	Value	Unit
Seasonal space heating energy efficiency $\eta_s$		101%	
Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 ° C and outdoor temperature $T_j$			
$T_j = - 7 ° C$	COPd or PERd	2.30	- or %
$T_j = + 2 ° C$	COPd or PERd	3.10	- or %
$T_j = + 7 ° C$	COPd or PERd	4.82	- or %
$T_j = + 12 ° C$	COPd or PERd	6.56	- or %
$T_j =$ bivalent temperature	COPd or PERd	2.30	- or %
$T_j =$ operation limit temperature	COPd or PERd	1.85	- or %
For air-to-water heat pumps: $T_j = -15 ° C$ (if TOL < -20°C)	COPd or PERd	x, xx	- or %
Cycling interval efficiency	COP <sub>cyc</sub> or PER <sub>cyc</sub>	x, xx	- or %

Annual electricity consumption (Low Temp)	Q HE, (Low Temp)	10167	kWh
Annual electricity consumption (Mid Temp)	Q HE (Mid Temp)	13720	kWh

- Commission regulation 327/2011 EU
- Reference standard ISO 12759:2010

**1. Product model information**

Requirements	Information
Overall efficiency ( $\eta$ )	45.7
Measurement category	A
Efficiency category	Static
Efficiency grade at optimum efficiency point	40
VSD (variable speed drives )	Yes
Year of manufacture	2025
Manufacturer's name or Trade Mark	LG Electronics Inc.
Commercial registration number	107-86-14075
Place of manufacturer	China
Product's model number	HM1**MRS UB4*
Rated power input(s) (kW)	0.17
Flow rate (m <sup>3</sup> /s)	1.732
Pressure (Pa)	40
Rotations per minute	550
The specific ratio	3.0

**2. Disassembly, recycling or disposal at end-of-life**

This product shall be disposed of separately from household-waste based on each local laws. When this product reaches its end of life, dispose of it at your local waste collection or recycling center.

**3. Installing, using and maintaining the fan**

Periodic maintenance and checks by a skilled & trained personnel are required to ensure that the product is maintained in good condition. In details, see the end product installation and owner's manual included in the end-product.